

Read these instructions before commencing installation. Please give these instructions to the owner/occupier after installation to retain for future reference/maintenance.

IP20     **240VAC~50HZ 16A**

Important Information

It is recommended that the track system is installed and fitted by a qualified electrician ensuring the installation complies to current IEE wiring regulations & local building control. These products are designed for use with the Escala Pro single circuit track system only. Any damaged parts should be replaced as soon as possible. KSR will not accept responsibility for any claims arising from a sub-standard installation.

Important User Advice

Always switch off mains supply before installing or servicing.
This product is designed to be used indoors only.

Installation Procedure

Remove the dead ends by loosening the retaining screw and sliding out the track.
Familiarize yourself with the way the live end connects to the track.
Insert the live end into track ensuring that it is inserted with the live connection aligned (The line on the track shows the live side) never force the connector (See Fig.1).
Tighten locking screw on the live end.





Fig. 1



KSR Lighting Aftersales: 023 92 674343
E-mail: aftersales@ksrlighting.com